

**From** Director General  
Fire Service, Haryana Panchkula

**To** M/s PM SHRI GSSS ASSANDH  
NEAR SALWAN CHOWK KARNAL ROAD ASSANDH  
Memo No. FS/2024/442 dated : 29/03/2024

**Subject :** Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B- Educational Building at NEAR SALWAN CHOWK KARNAL ROAD ASSANDH of PM SHRI GSSS ASSANDH :

Reference your Transaction Id 100642323000032 dated: 23/12/2023 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Karnal, .The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

Tower Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage
Block A	Ground	4.26 mtr.	1057.42 Sq. mtr.
Block B	Ground	4.26 mtr.	592.95 Sq. mtr.
Block C	G+1	8.52 mtr.	823.14 Sq. mtr.
Block D	Ground	4.26 mtr.	503.62 Sq. mtr.
Block E	Ground	4.26 mtr.	242.87 Sq. mtr.
Bath & Porch	Ground	4.26 mtr.	145.34 Sq. mtr.
Tower Name	Basement Level	Basement Area	Basement Remarks
	Nil	Nil	Nil

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

**Remarks:- ok**



**It is certified that the fire NOC has been applied and it will be provided to your office with in the period of three months**

Deputy Director (Technical)-I,  
for Director General, Fire  
Service, Haryana  
Panchkula  
Digitally signed by GULSHAN  
KALRA  
Date: 2024.03.29 16:29:57 +05:30  
Reason: Digital Signature  
Exerci



# PM SHRI GOVT. SR. SEC. SCHOOL

Near Salwan Chowk, Karnal Road, Assandh, Distt. Karnal - 132039  
School Code : 1768

✉ gsssasd1768@gmail.com 🌐 www.pmsdrigsssasd1768.com



Ref. No. GSSS/Asd/2023-24/2920

Dated. 06.04.2024

To

The Fire Officer.  
Fire Brigade Services Centre,  
Karnal.

**Subject: Request for Issuance of Fire NOC.**

Sir,

As you are aware, ensuring the safety and security of our students, staff, and premises is our utmost priority. In line with this commitment, we have diligently worked on formulating a comprehensive Fire Fighting Scheme for our school premises. Our scheme has been meticulously designed, considering all relevant safety regulations and protocols.

After thorough examination and scrutiny, our Fire Fighting Scheme has been approved by the concerned authorities vide Memo No. FS/2024/442 dated 29.03.2024. Now, to fully implement this scheme and enhance the safety measures on our premises, we require the issuance of the NOC from your esteemed department.

We assure you that all necessary arrangements and installations as per the approved scheme have been duly completed. Our school is fully prepared to comply with all fire safety regulations and protocols, and we are ready to obtain the NOC to validate our adherence to these standards.

Therefore, we kindly request you to expedite the process of issuing the NOC for our school premises at your earliest convenience. We are grateful for your attention to this matter and eagerly await a favorable response from your end.

Thank you for your cooperation and understanding.

- Encls : 1. Copy Approved Fire Fighting Scheme  
2. Copy of PAN & Adhaar Care Copy of Principal  
3. TAN Number of School

  
Principal  
Govt. Sr. Sec. School  
PRINCIPAL  
Assandh, Distt. Karnal